

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# CERTIFICATE

No. B 104593 0003 Rev. 00

**Holder of Certificate:** Zhejiang Saint Magnesium Electric Co., Ltd.

No. 8-1 Linshi Road, Linchuan Industrial Zone, Songmen Town  
317500 Wenling City, Taizhou City  
PEOPLE'S REPUBLIC OF CHINA

**Production Facility(ies):** 104593  
**Certification Mark:**



**Product:** Circuit Breaker for Equipment

**Model(s):** S10

**Parameters:**

Rated voltage: AC 125V, AC 250V, DC 65V  
Rated frequency: 50/60Hz for a.c.  
Rated current: 3A, 4A, 5A, 6A, 7A, 8A, 9A, 10A, 11A, 12A, 13A, 14A, 15A, 16A  
Pole No.: 1 pole  
Method of operation: R-type, J-type  
Rated short-circuit capacity (Icn): 10In  
Rated conditional short-circuit current (Inc1): 1000A  
Mode of tripping: Thermal (TO)  
Trip free behaviour: Cycling trip-free  
Pollution degree: 2

**Tested according to:** EN 60934:2001/A2:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704101983001-00  
**Valid until:** 2024-11-03

**Date,** 2019-11-04

( Jie Zhu )