



Product Service

# Attestation of Conformity

No. N8A 104593 0006 Rev. 00

**Holder of Certificate:** **Zhejiang Saint Magnesium Electric Co., Ltd.**

No. 8-1 Linshi Road, Linchuan Industrial Zone, Songmen Town  
317500 Wenling City, Taizhou City  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Circuit Breaker for Equipment**  
**Model(s):** **S11**

<b>Parameters:</b>	Rated voltage:	AC 125V, AC 250V, DC 65V
	Rated frequency:	50/60Hz for a.c.
	Rated current:	3A, 4A, 5A, 6A, 7A, 8A, 9A, 10A, 11A, 12A, 13A, 14A, 15A, 16A, 17A, 18A, 19A, 20A, 21A, 22A, 23A, 24A, 25A, 26A, 27A, 28A, 29A, 30A
	Pole No.:	1 pole
	Method of operation:	R-type, J-type
	Rated short-circuit capacity (Icn):	10In
	Rated conditional short-circuit current (Inc1):	1000A
	Mode of tripping:	Thermal (TO)
	Trip free behaviour:	Cycling trip-free
	Pollution degree:	2

EN 60934:2001/A2:2013

## Tested according to:

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.

It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704101983002-00

**Date,** 2019-11-05

  
( Jie Zhu )

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany



ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT