

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. B 104593 0005 Rev. 00

Holder of Certificate: Zhejiang Saint Magnesium Electric Co., Ltd.

No. 8-1 Linshi Road, Linchuan Industrial Zone, Songmen Town
317500 Wenling City, Taizhou City
PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): 104593
Certification Mark:



Product: Circuit Breaker for Equipment

Model(s): S11

Parameters:	Rated voltage:	AC 125V, AC 250V, DC 65V
	Rated frequency:	50/60Hz for a.c.
	Rated current:	3A, 4A, 5A, 6A, 7A, 8A, 9A, 10A, 11A, 12A, 13A, 14A, 15A, 16A, 17A, 18A, 19A, 20A, 21A, 22A, 23A, 24A, 25A, 26A, 27A, 28A, 29A, 30A
	Pole No.:	1 pole
	Method of operation:	R-type, J-type
	Rated short-circuit capacity (Icn):	10In
	Rated conditional short-circuit current (Inc1):	1000A
	Mode of tripping:	Thermal (TO)
	Trip free behaviour:	Cycling trip-free
	Pollution degree:	2

Tested according to: EN 60934:2001/A2:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101983002-00
Valid until: 2024-11-03

Date, 2019-11-04

(Jie Zhu)