



Certificate of Compliance

Certificate: 80014055 **Master Contract:** 300575
Project: 80014055 **Date Issued:** 2019-08-28
Issued to: Zhejiang Fang Yuan Electric Equipment Test Co., Ltd
No.400, Guangqiong Road,
Jiaxing, Zhejiang 314000,
CHINA
Attention: Mr. Maojun Guo

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only, and



Issued by: *Larry Liu*
Larry Liu

PRODUCTS

CLASS - C321530 - SUPPLEMENTARY PROTECTORS-COMPONENT ACCEPTANCE PROGRAM
CLASS - C321590 - SUPPLEMENTARY PROTECTORS-Component Acceptance-Certified to U.S. Standards

Supplementary Protectors, general use, overcurrent trip, bimetal type, single phase, manual reset with no-manual switching feature, models and ratings as table below,

Cat. No.	Type	UG	FW	Max V	A	TC	OL	SC	Trip Type
S11 Series	OC	A	3	125/250Vac	3-30	1	1	1.0kA, C1; 0.4kA, U3	Cycling
	OC	A	3	65Vdc	3-30	1	1	0.4kA, C1; 0.4kA, U3	Trip Free
S22 Series	OC	A	3	125/250Vac	5-50	1	1	1.0kA, C1; 0.5 kA, U3	Cycling
	OC	A	3	65Vdc	5-50	1	1	0.5kA, C1; 0.4kA, U3	Trip Free

Notes:

1. These are sold to manufacturers for the assembly as components of certified electrical equipment where the suitability of the combination is determined by CSA International.
2. These devices are not suitable for branch circuit protection.
3. All supplementary protectors listed have been investigated for use only in a 25°C ambient maximum.